

Effective 5/12/2015

15A-5-102 Definitions.

As used in this chapter:

- (1) "Appreciable depth" means a depth greater than 1/4 inch.
- (2) "AHJ" means "authority having jurisdiction," which is:
 - (a) the State Fire Marshal;
 - (b) an authorized deputy of the State Fire Marshal; or
 - (c) the local fire enforcement authority.
- (3) "Division" means the State Fire Marshal Division created in Section 53-7-103.
- (4)
 - (a) "Dwelling Unit" means one or more rooms arranged for the use of one or more individuals living together, as in a single housekeeping unit normally having cooking, living, sanitary, and sleeping facilities.
 - (b) "Dwelling unit" includes a hotel room, dormitory room, apartment, condominium, sleeping room in a nursing home, or similar living unit.
- (5) "Fire jurisdiction" means a contiguous geographic area for which there is a single authority having jurisdiction.
- (6) "IFC" means the edition of the International Fire Code adopted under Section 15A-5-103.
- (7) "NFPA" means the edition of the National Fire Protection Association adopted under Section 15A-5-103.
- (8) "Premixed" means the state of an antifreeze and water solution that results from the solution being prepared by the manufacturer with a quality control procedure that ensures that the antifreeze and water solution does not separate.
- (9) "UL" means Underwriters Laboratories, Inc.

Amended by Chapter 158, 2015 General Session