



UTAH STATE SENATE

UTAH STATE CAPITOL COMPLEX • 320 STATE CAPITOL
P.O. BOX 145115 • SALT LAKE CITY, UTAH 84114-5115 • (801) 538-1035

February 10, 2011

Mr. President:

The Business and Labor Committee reports a favorable recommendation on **H.B. 203**, CODIFICATION OF STATE CONSTRUCTION AND FIRE CODES, by Representative M. Morley, with the following amendments:

1. *Page 115, Lines 3150 through 3153*

House Floor Amendments

2-8-2011:

- 3150 is added as follows: "Fire flow may be reduced for an isolated one- and two-family dwelling
- 3151 when the authority having jurisdiction over the dwelling determines that the development of a
- 3152 full fire-flow requirement is impractical."
- 3152a H→ (c) In IFC, Chapter 5, a new Section 507.1.2, Pre-existing subdivision lots, is added as
- 3152b follows " {~~Fire flow~~} **Total water supply** requirements shall not exceed the fire flows described in {~~Subsection~~
- 3152c** {~~2(a)(iv)~~} **Section 501.5(iv)** for {~~a~~} **the largest** one- or two-family dwelling, protected by an automatic fire sprinkler system, on
- 3152d a subdivision lot platted before December 31, 1980, unless the municipality or county in which

Bill Number



HB0203

Action Class



S

Action Code



SCRAMD

3152e the lot is located provides the required fire flow capacity.” ←H
3153 (3) For IFC, Building Services and Systems:

Respectfully,

John L. Valentine
Committee Chair

Voting: 6-0-2

3 HB0203.SCI.WPD /BRH PO/BRH 2/10/11 4:06 pm

Bill Number



HB0203

Action Class



S

Action Code



SCRAMD