

Superseded 7/1/2016

15A-3-110 Amendments to Chapters 23 through 25 of IBC.

- (1) A new IBC, Section 2306.1.5, is added as follows: "2306.1.5 Load duration factors. The allowable stress increase of 1.15 for snow load, shown in Table 2.3.2, Frequently Used Load Duration Factors, Cd, of the National Design Specifications, shall not be utilized at elevations above 5,000 feet (1,524 M)."
- (2) In IBC, Section 2308.6, a new exception is added as follows: "Exception: Where foundation plates or sills are bolted or anchored to the foundation with not less than 1/2 inch (12.7 mm) diameter steel bolts or approved anchors, embedded at least 7 inches (178 mm) into concrete or masonry and spaced not more than 32 inches (816 mm) apart, there shall be a minimum of two bolts or anchor straps per piece located not less than 4 inches (102 mm) from each end of each piece. A properly sized nut and washer shall be tightened on each bolt to the plate."
- (3) IBC, Section 2506.2.1, is deleted and replaced with the following: "2506.2.1 Other materials. Metal suspension systems for acoustical and lay-in panel ceilings shall conform with ASTM C635 listed in Chapter 35 and Section 13.5.6 of ASCE 7, as amended in Section 1613.8, for installation in high seismic areas."