

Effective 7/1/2014

Superseded 7/1/2016

15A-3-701 General provisions.

The following is adopted as an amendment to the IECC to be applicable statewide:

- (1) In IECC, Section C202, the definition for "CONDITIONED SPACE" is deleted and replaced with the following: "CONDITIONED SPACE. An area, room or space enclosed within the building thermal envelope that is directly heated or cooled, or indirectly heated or cooled by any of the following means:
 1. Openings directly into an adjacent conditioned space.
 2. An un-insulated floor, ceiling or wall adjacent to a conditioned space.
 3. Un-insulated duct, piping or other heat or cooling source within the space."
- (2) In IECC, Section C404.4, a new exception is added as follows: "Exception: Heat traps, other than the arrangement of piping and fittings, shall be prohibited unless a means of controlling thermal expansion can be ensured as required in the IPC Section 607.3."
- (3) In IECC, Section R103.2, all words after the words "herein governed." are deleted and replaced with the following: "Construction documents include all documentation required to be submitted in order to issue a building permit."
- (4) In IECC, Section R202, the definition for "CONDITIONED SPACE" is deleted and replaced with the following: "CONDITIONED SPACE. An area, room or space enclosed within the building thermal envelope that is directly heated or cooled, or indirectly heated or cooled by any of the following means:
 1. Openings directly into an adjacent conditioned space.
 2. An un-insulated floor, ceiling or wall adjacent to a conditioned space.
 3. Un-insulated duct, piping or other heat or cooling source within the space."
- (5) In IECC, Section R303.3, all wording after the first sentence is deleted.
- (6) In IECC, Table R402.1.1 and Table R402.1.3, the rows for "climate zone 3", "climate zone 5 and Marine 4, and climate zone 6" are deleted and replaced and a new footnote j is added as follows:

"TABLE R402.1.1										
INSULATION AND FENESTRATION REQUIREMENTS BY COMPONENT ^a										
CLIMATE ZONE	FENESTRATION U-FACTOR ^b	SKYGLAZED FENESTRATION U-FACTOR ^b	SKYGLAZED FENESTRATION SHGC ^{b,e}	CEILING PARTITION VALUE	WOOD FRAME WALL R-VALUE	MASS WALL R-VALUE ^{i, j}	FLOOR R-VALUE	BASEMENT WALL R-VALUE	SLAB R-VALUE & DEPTH ^d	CRAWL SPACE WALL R-VALUE ^c
3	0.65	0.65	0.40	30	15	5	19	0	0	5/13
5 and Marine 4	0.35	0.60	NR	38	19 or 13 + 5h	13	30 g	10/13	10, 2 ft	10/13
6	0.35	0.60	NR	49	19 or 13 + 5h	15	30 g	10/13	10, 4 ft	10/13

j. Log walls complying with ICC400 and with a minimum average wall thickness of 5" or greater shall be permitted in Zones 5-8 when overall window glazing is .31 U-factor or lower,

minimum heating equipment efficiency is 90 AFUE (gas) or 84 AFUE (oil), and all other component requirements are met.

TABLE R402.1.3 EQUIVALENT U-FACTORS^a

CLIMATE ZONE	FENESTRATION U-FACTOR	SKYLIGHT U-FACTOR	CEILING U-FACTOR	FRAME WALL U-FACTOR	MASS WALL U-FACTOR ^b	FLOOR U-FACTOR	BASEMENT WALL U-FACTOR	CRAWL SPACE WALL U-FACTOR
3	0.65	0.65	0.035	0.082	0.141	0.047	0.360	0.136
5 and Marine 4	0.35	0.60	0.030	0.060	0.082	0.033	0.059	0.065
6	0.35	0.60	0.026	0.060	0.060	0.033	0.059	0.065

- (7) In IECC, Section R402.2.1, the last sentence is deleted.
- (8) In IECC, Section R402.2.2, the last sentence is deleted.
- (9) In IECC, Section R402.3.3, the last sentence is deleted.
- (10) In IECC, Section R402.3.4, the last sentence is deleted.
- (11) In IECC, Section R402.4.1, in the first sentence, the word "and" is deleted and replaced with the word "or".
- (12) In IECC, Section R402.4.1.1, the last sentence is deleted and replaced with the following:
"Where allowed by the building official, the builder may certify compliance to components criteria for items which may not be inspected during regularly scheduled inspections."
- (13) In IECC, Section R402.4.1.2, the following changes are made:
 - (a) In the first sentence, the words "in Zones 1 and 2, and 3 air changes per hour in Zone 3 through 8" are deleted.
 - (b) In the third sentence, the words "Where required by the building official," and the word "third" are deleted.
 - (c) The following sentence is inserted after the third sentence: "The following parties shall be approved to conduct testing: Parties certified by BPI or RESNET, or licensed contractors who have completed training provided by Blower Door Test equipment manufacturers or other comparable training."
- (14) In IECC, Section R402.4.4, the last sentence is deleted.
- (15) In IECC, Section R403.2.2, the requirements for duct tightness testing are deleted and replaced with the following:
 - 1. Postconstruction test: Total leakage shall be less than or equal to 10 cfm (283 L/min) per 100 square feet (9.29 m²) of conditioned floor space when tested at a pressure differential of 0.1 inches w.g. (25 Pa) across the entire system, including the manufacturer's air handler enclosure. All register boots shall be taped or otherwise sealed during the test.
 - 2. Rough-in test: Total leakage shall be less than or equal to 10 cfm (283 L/min) per 100 square feet (9.29 m²) of conditioned floor area when tested at a pressure differential of at least 0.1 inches w.g. (25 Pa) across the system, including the manufacturer's air handler enclosure. All registers shall be taped or otherwise sealed during the test. If the air handler is not installed at the time of the test, total leakage shall be less than or equal to 7.5 cfm (212 L/min) per 100 square feet (9.29 m²) of conditioned floor area."
- (16) In IECC, Section R403.2.2, the exception for total leakage testing is deleted and replaced with the following: "Exception: The total leakage test is not required for systems with all air handlers"

and at least 50% of all ducts (measured by length) located entirely within the building thermal envelope."

- (17) In IECC, Section R403.2.3, the words "or plenums" are deleted.
- (18) In IECC, Section R403.4.2, the sentences for "3." and "9." and the last sentence are deleted.
- (19) In IECC, Section R403.5, the first sentence is deleted.
- (20) IECC, Section R404.1 and the exception are deleted, and R404.1.1 becomes R404.1.
- (21) In IECC, Table R405.5.2(1), the following changes are made under the column STANDARD REFERENCE DESIGN:
 - (a) In the row "Air exchange rate", the words "in Zones 1 and 2, and 3 air changes per hour in Zones 3 through 8" are deleted.
 - (b) In the row "Heating systemsf, g", the standard reference design is deleted and replaced with the following:
 - "Fuel Type: same as proposed design
 - Efficiencies:
 - Electric: air source heat pump with prevailing federal minimum efficiencies
 - Nonelectric furnaces: natural gas furnace with prevailing federal minimum efficiencies
 - Nonelectric boilers: natural gas boiler with prevailing federal minimum efficiencies
 - Capacity: sized in accordance with Section N1103.6"
 - (c) In the row "Cooling systemsf, h" the words "As proposed" are deleted and replaced with the following:
 - "Fuel Type: Electric
 - Efficiency: in accordance with prevailing federal minimum standards"
 - (d) In the row "Service water heatingf, g, h, i", the words "As proposed" are deleted and replaced with the following:
 - "Fuel Type: same as proposed design Efficiency: in accordance with prevailing federal minimum standards
 - Tank Temperature: 120o F"
 - (e) In the row "Thermal distribution systems" the word "none" is deleted and replaced with the following: "Thermal distribution system efficiency (DSE) of .080 shall be applied to both the heating and cooling system efficiencies."
- (22) In IECC, Table R405.5.2(2), the number "0.80" is inserted under "Forced air systems" for "Distribution system components located in unconditioned space".
- (23) The RESCheck Software adopted by the United States Department of Energy and modified to meet the requirements of this section shall be used to verify compliance with this section. The software shall address the Total UA alternative approach and account for Equipment Efficiency Trade-offs when applicable per the standard reference design as amended.