

**Superseded 7/1/2016**

**15A-4-107 Amendments to IBC applicable to Sandy City.**

The following amendments are adopted as amendments to the IBC for Sandy City:

- (1) A new IBC, Section (F)903.2.13, is added as follows: "(F)903.2.13 An automatic sprinkler system shall be installed in accordance with NFPA 13 throughout buildings containing all occupancies where fire flow exceeds 2,000 gallons per minute, based on Table B105.1 of the 2009 International Fire Code. Exempt locations as indicated in Section 903.3.1.1.1 are allowed.

Exception: Automatic fire sprinklers are not required in buildings used solely for worship, Group R Division 3, Group U occupancies and buildings complying with the International Residential Code unless otherwise required by the International Fire Code.

- (2) A new IBC, Appendix L, is added and adopted as follows: "Appendix L BUILDINGS AND STRUCTURES CONSTRUCTED IN AREAS DESIGNATED AS WILDLAND-URBAN INTERFACE AREAS

AL 101.1 General. Buildings and structures constructed in areas designated as Wildland-Urban Interface Areas by Sandy City shall be constructed using ignition resistant construction as determined by the Fire Marshal. Section 502 of the 2006 International Wildland-Urban Interface Code (IWUIC), as promulgated by the International Code Council, shall be used to determine Fire Hazard Severity. The provisions listed in Chapter 5 of the 2006 International Wildland-Urban Interface Code, as modified herein, shall be used to determine the requirements for Ignition Resistant Construction.

(i) In Section 504 of the IWUIC Class I IGNITION-RESISTANT CONSTRUCTION a new Section 504.1.1 is added as follows: "504.1.1 General. Subsections 504.5, 504.6, and 504.7 shall only be required on the exposure side of the structure, as determined by the Fire Marshal, where defensible space is less than 50 feet as defined in Section 603 of the 2006 International Wildland-Urban Interface Code.

(ii) In Section 505 of the IWUIC Class 2 IGNITION-RESISTANT CONSTRUCTION Subsections 505.5 and 505.7 are deleted."