

Effective 7/1/2016

15A-5-205.5 Amendments to Chapter 11 of IFC.

- (1) In IFC, Chapter 11, Section 1103.2 Emergency Responder Radio Coverage in Existing Buildings, is amended as follows: On line two after the title, the following is added: "When required by the fire code official".
- (2) IFC, Chapter 11, Section 1103.5.1 Group A-2, is deleted and replaced with the following: "1103.5.1 Group A-2. An automatic fire sprinkler system shall be provided throughout existing Group A-2 occupancies where indoor pyrotechnics are used."
- (3) IFC, Chapter 11, Section 1103.6, Standpipes, is deleted.
- (4) In IFC, Chapter 11, 1103.7, Fire Alarm Systems, is deleted and rewritten as follows: "1103.7, Fire Alarm Systems. The following shall have an approved fire alarm system installed in accordance with Utah Administrative Code Section R710-4: 1. a building with an occupant load of 300 or more persons that is owned or operated by the state; 2. a building with an occupant load of 300 or more persons that is owned or operated by an institution of higher education; and 3. a building with an occupant load of 50 or more persons that is owned or operated by a school district, private school, or charter school.
Exception: the requirements of this section do not apply to a building designated as an Institutional Group I (as defined in IFC 202) occupancy."
- (5) IFC, Chapter 11, 1103.7.1 Group E, 1103.7.2 Group I-1, 1103.7.3 Group I-2, 1103.7.4 Group I-3, 1103.7.5 Group R-1, 1103.7.5.1 Group R-1 Hotel and Motel Manual Fire Alarm System, 1103.7.5.1.1 Group R-1 Hotel and Motel Automatic Smoke Detection System, 1103.7.5.2 Group R-1 Boarding and Rooming Houses Manual Fire Alarm System, 1103.7.5.2.1 Group R-1 Boarding and Rooming Houses Automatic Smoke Detection System, 1103.7.6 Group R-2 and 1103.7.7 Group R-4, are deleted.
- (6) IFC, Chapter 11, Section 1103.9, Carbon Monoxide Alarms, is deleted and rewritten as follows: "1103.9 Carbon Monoxide Detection.
Existing Groups E, I-1, I-2, I-4, and R occupancies shall be equipped with carbon monoxide detection in accordance with Section 915."

Amended by Chapter 216, 2016 General Session