

53-7-217 Portable fire extinguishers -- Permit required to perform hydrostatic testing.

Each firm performing hydrostatic testing of portable fire extinguishers shall:

- (1) perform the tests in accordance with the specifications of the United States Department of Transportation for compressed gas cylinders; and
- (2) obtain a permit from the division by applying in writing on forms provided by the division.

Renumbered and Amended by Chapter 234, 1993 General Session