

H.B. 203

CODIFICATION OF STATE CONSTRUCTION AND FIRE CODES

SENATE COMMITTEE AMENDMENTS

AMENDMENT 6

FEBRUARY 10, 2011 11:19 AM

Senator _____ proposes the following amendments:

1. *Page 115, Lines 3150 through 3153*

House Floor Amendments

2-8-2011:

- 3150 is added as follows: "Fire flow may be reduced for an isolated one- and two-family dwelling
3151 when the authority having jurisdiction over the dwelling determines that the development of a
3152 full fire-flow requirement is impractical."
- 3152a ~~Ë~~→ (c) In IFC, Chapter 5, a new Section 507.1.2, Pre-existing subdivision lots, is added as
3152b follows " {~~Fire flow~~} ~~Total water supply~~ requirements shall not exceed the fire flows described in
{Subsection
3152c ~~(2)(a)(iv)}~~ Section 501.5(iv) for ~~{a}~~ the largest one- or two-family dwelling, protected by an
automatic fire sprinkler system, on
3152d a subdivision lot platted before December 31, 1980, unless the municipality or county in which
3152e the lot is located provides the required fire flow capacity." ←Ë
3153 (3) For IFC, Building Services and Systems: