

# H.B. 310

## CONSTRUCTION CODE AMENDMENTS

Representative **Brad R. Wilson** proposes the following amendments:

1. *Page 2, Lines 44 through 46:*

44 15A-3-310, as enacted by Laws of Utah 2011, Chapter 14  
45 = 15A-3-311, as enacted by Laws of Utah 2011, Chapter 14  
15A-3-313, as enacted by Laws of Utah 2011, Chapter 14  
46 15A-3-314, as enacted by Laws of Utah 2011, Chapter 14

2. *Page 17, Lines 518 through 520:*

518 [(H)] (8) IBC, [Subsections] Sections (F)904.11.3, (F)904.11.3.1, (F)904.11.4, and  
519 (F)904.11.4.1, are deleted.

(9) IBC, Section (F)907.2.3 Group E:

(a) The first sentence is deleted and rewritten as follows: "A manual fire alarm system that initiates the occupant notification system in accordance with Section (F) 907.5 and installed in accordance with Section (F) 907.6 shall be installed in Group E occupancies."

(b) In Exception number 3, starting on line five, the words "emergency voice/alarm communication system are deleted and replaced with "occupant notification system".

520 [(12)] A new IBC, Section (F)907.9, is added as follows: "Section (F)907.9 Carbon

3. *Page 18, Lines 529 through 531:*

529 (9) In IBC, Section (F)908.7, the first sentence is deleted and replaced as follows: "Groups R-1, R-2, R-3, R-4, I-1, and I-4 occupancies"; the exceptions are deleted and the following sentence is  
530 added after the first sentence: "A minimum of one carbon monoxide alarm shall be installed on  
531 each habitable level."

4. *Page 32, Lines 928 through 932:*

928 Section 11. Section **15A-3-113** is amended to read:

929 15A-3-113. Amendments to Chapters 32 through 35 of IBC.

930 (1) A new section IBC, Section {~~3401.6~~} 3401.7, is added as follows:

" {~~3401.6~~} 3401.7 Parapet bracing,

931 wall anchors, and other appendages. Until June 30, 2014, a building constructed before 1975

932 shall have parapet bracing, wall anchors, and appendages such as cornices, spires, towers,

5. Page 74, Lines 1740 through 1742:

1740 [(8)] (10) In IPC, Section 608.6, the following sentence is added at the end of the  
1741 paragraph: "Any connection between potable water piping and sewer-connected waste shall be  
1742 protected by an air gap in accordance with Section {~~308.13.1~~} 608.13.1 ."

6. Page 79, Lines 1900 through 1901:

1900 terminate out the roof. The flow control device shall be installed in accordance with the  
1901 manufacturers instructions."

**Section 25. Section 15A-3-311 is amended to read:**

**15A-3-311. Amendments to Chapter 11 of IPC.**

(1) IPC, Section 1104.2, is deleted and replaced with the following: "1104.2 Combining storm and sanitary drainage prohibited. The combining of sanitary and storm drainage systems is prohibited."

(2) IPC, Section {~~1108~~} 1109 , is deleted.

**Renumber remaining sections accordingly.**