

1st Sub. S.B. 143

NAIL TECHNICIAN PRACTICE AMENDMENTS

Senator **Todd Weiler** proposes the following amendments:

1. *Page 2, Lines 46 through 51:*

- 46 (4) In IMC, Table 403.3, Note h is deleted and replaced with the following: "1. For a
47 nail salon where a nail technician files or shapes an acrylic nail, **as defined by rule by the Division of**
Occupational and Professional Licensing, in accordance with Title 63G, Chapter 3, Utah Administrative
Rulemaking Act, each nail station where a nail
48 technician files or shapes an acrylic nail shall be provided with:
49 a. a source capture system capable of filtering and recirculating air to inside space not
50 less than 50 cfm per station; or
51 b. a source capture system capable of exhausting not less than 50 cfm per station. "
2. Except as provided in paragraph 3, the requirements described in paragraph 1 apply beginning
on July 1, 2020.
3. The requirements described in paragraph 1 apply beginning on July 1, 2014 if the nail salon is
under or begins new construction or remodeling on or after July 1, 2014. "