



House of Representatives *State of Utah*

UTAH STATE CAPITOL COMPLEX • 350 STATE CAPITOL
P.O. BOX 145030 • SALT LAKE CITY, UTAH 84114-5030 • (801) 538-1029

February 27, 2017

Mr. Speaker,

The Business and Labor Committee reports a favorable recommendation on **1st Sub. S.B. 145**, NAIL SALON AMENDMENTS, by Senator T. Weiler, with the following amendments and recommends it be placed on the Consent Calendar.

1. Page 2, Lines 53 through 55:

- 53 a. a source capture system equipped with at minimum, a MERV 8 particulate {
54 filer} filter and
54 an activated carbon filter that is capable of filtering and recirculating air to inside space at
55 a
55 rate not less than 50 cfm per station; or

Respectfully,

James A. Dunnigan
Chair

Voting: 10-0-4

5 SB0145.HC1.wpd 2/27/17 6:4 pm menewbold/MEN SJ/AJS

Bill Number



SB0145S01

Action Class



H

Action Code



HCRAMDCON