

Senator Curtis S. Bramble proposes the following substitute bill:

UNIFORM CONSTRUCTION CODE AMENDMENTS

2018 GENERAL SESSION

STATE OF UTAH

Chief Sponsor: Mike Schultz

Senate Sponsor: Curtis S. Bramble

LONG TITLE

General Description:

This bill amends the State Construction and Fire Codes Act.

Highlighted Provisions:

This bill:

▶ adds the definition of a "motor vehicle waste disposal well" to the International Plumbing Code;

▶ adds a section regarding the prohibition of certain motor vehicle waste disposal wells to the International Plumbing Code;

▶ amends the International Residential Code;

▶ incorporates by reference the 2017 edition of the National Electrical Code;

▶ amends incorporated provisions of the National Electrical Code; and

▶ makes technical changes.

Money Appropriated in this Bill:

None

Other Special Clauses:

None

Utah Code Sections Affected:

AMENDS:



- 26 **15A-2-103**, as last amended by Laws of Utah 2016, Chapter 249
- 27 **15A-3-206**, as last amended by Laws of Utah 2017, Chapter 236
- 28 **15A-3-302**, as last amended by Laws of Utah 2016, Chapter 249
- 29 **15A-3-304**, as last amended by Laws of Utah 2016, Chapter 249
- 30 **15A-3-601**, as last amended by Laws of Utah 2016, Chapter 249



31 *Be it enacted by the Legislature of the state of Utah:*

32 Section 1. Section **15A-2-103** is amended to read:

33 **15A-2-103. Specific editions adopted of construction code of a nationally**
34 **recognized code authority.**

35 (1) Subject to the other provisions of this part, the following construction codes are
36 incorporated by reference, and together with the amendments specified in Chapter 3, Part 3,
37 Statewide Amendments to International Plumbing Code, and Chapter 4, Local Amendments
38 Incorporated as Part of State Construction Code, are the construction standards to be applied to
39 building construction, alteration, remodeling, and repair, and in the regulation of building
40 construction, alteration, remodeling, and repair in the state:

41 (a) the 2015 edition of the International Building Code, including Appendix J, issued
42 by the International Code Council;

43 (b) the 2015 edition of the International Residential Code, issued by the International
44 Code Council;

45 (c) the 2015 edition of the International Plumbing Code, issued by the International
46 Code Council;

47 (d) the 2015 edition of the International Mechanical Code, issued by the International
48 Code Council;

49 (e) the 2015 edition of the International Fuel Gas Code, issued by the International
50 Code Council;

51 (f) the ~~2014~~ 2017 edition of the National Electrical Code, issued by the National Fire
52 Protection Association;

53 (g) the 2015 edition of the International Energy Conservation Code, issued by the
54 International Code Council;

55 (h) the 2015 edition of the International Existing Building Code, issued by the
56

57 International Code Council;

58 (i) subject to Subsection 15A-2-104(2), the HUD Code;

59 (j) subject to Subsection 15A-2-104(1), Appendix E of the 2015 edition of the
60 International Residential Code, issued by the International Code Council; and

61 (k) subject to Subsection 15A-2-104(1), the 2005 edition of the NFPA 225 Model
62 Manufactured Home Installation Standard, issued by the National Fire Protection Association.

63 (2) Consistent with Title 65A, Chapter 8, Management of Forest Lands and Fire
64 Control, the Legislature adopts the 2006 edition of the Utah Wildland Urban Interface Code,
65 issued by the International Code Council, with the alternatives or amendments approved by the
66 Utah Division of Forestry, as a construction code that may be adopted by a local compliance
67 agency by local ordinance or other similar action as a local amendment to the codes listed in
68 this section.

69 Section 2. Section 15A-3-206 is amended to read:

70 **15A-3-206. Amendments to Chapters 39 and 44 and Appendix F of IRC.**

71 (1) In IRC, Section E3705.4.5, the following words are added after the word
72 "assemblies": "with ungrounded conductors 10 AWG and smaller".

73 [~~1~~] (2) In IRC, Section E3901.9, the following exception is added:
74 "Exception: Receptacles or other outlets adjacent to the exterior walls of the garage, outlets
75 adjacent to an exterior wall of the garage, or outlets in a storage room with entry from the
76 garage may be connected to the garage branch circuit."

77 [~~2~~] (3) IRC, Section E3902.16 is deleted.

78 [~~3~~] (4) In Section E3902.17:

- 79 (a) following the word "Exception" the number "1." is added; and
- 80 (b) at the end of the section, the following sentences are added:

81 "2. This section does not apply for a simple move or an extension of a branch circuit or an
82 outlet which does not significantly increase the existing electrical load. This exception does
83 not include changes involving remodeling or additions to a residence."

84 [~~4~~] (5) IRC, Chapter 44, is amended by adding the following reference standard:

"Standard reference number	Title	Referenced in code section number

<p>86 USC-FCCCHR 10th Edition Manual of Cross Connection Control</p>	<p>Foundation for Cross-Connection Control and Hydraulic Research University of Southern California Kaprielian Hall 300 Los Angeles CA 90089-2531</p>	<p>Table P2902.3"</p>
--	---	-----------------------

87 [~~5~~] (6) (a) When passive radon controls or portions thereof are voluntarily installed,
 88 the voluntary installation shall comply with Appendix F of the IRC.

89 (b) An additional inspection of a voluntary installation described in Subsection [~~5~~]
 90 (6)(a) is not required.

91 Section 3. Section **15A-3-302** is amended to read:

92 **15A-3-302. Amendments to Chapters 1 and 2 of IPC.**

93 (1) A new IPC, Section 101.2.1, is added as follows: "For clarification, the
 94 International Private Sewage Disposal Code is not part of the plumbing code even though it is
 95 in the same printed volume."

96 (2) In IPC, Section 202, the definition for "Backflow Backpressure, Low Head" is
 97 deleted.

98 (3) In IPC, Section 202, the following definition is added: "Certified Backflow
 99 Preventer Assembly Tester. A person who has shown competence to test Backflow prevention
 100 assemblies to the satisfaction of the authority having jurisdiction under Utah Code, Subsection
 101 **19-4-104(4)**."

102 (4) In IPC, Section 202, the following definition is added: "Contamination (High
 103 Hazard). An impairment of the quality of the potable water that creates an actual hazard to the
 104 public health through poisoning or through the spread of disease by sewage, industrial fluids or
 105 waste."

106 (5) In IPC, Section 202, the definition for "Cross Connection" is deleted and replaced
 107 with the following: "Cross Connection. Any physical connection or potential connection or
 108 arrangement between two otherwise separate piping systems, one of which contains potable
 109 water and the other either water of unknown or questionable safety or steam, gas, or chemical,
 110 whereby there exists the possibility for flow from one system to the other, with the direction of
 111 flow depending on the pressure differential between the two systems (see "Backflow")."

112 (6) In IPC, Section 202, the following definition is added: "Deep Seal Trap. A
 113 manufactured or field fabricated trap with a liquid seal of 4" or larger."

114 (7) In IPC, Section 202, the definition for "Essentially Nontoxic Transfer Fluid" is
115 deleted and replaced with the following:

116 "ESSENTIALLY NONTOXIC TRANSFER FLUID. Fluids having a Gosselin rating of 1,
117 including propylene glycol; and mineral oil."

118 (8) In IPC, Section 202, the definition for "Essentially Toxic Transfer Fluid" is deleted
119 and replaced with the following:

120 "ESSENTIALLY TOXIC TRANSFER FLUID. Soil, waste, or gray water; and any fluid that is
121 not an essentially nontoxic transfer fluid under this code."

122 (9) In IPC, Section 202, the following definition is added: "High Hazard. See
123 Contamination."

124 (10) In IPC, Section 202, the following definition is added: "Low Hazard. See
125 Pollution."

126 (11) In IPC, Section 202, the following definition is added: "Motor vehicle waste
127 disposal well. An injection well that discharges to the subsurface by way of a floor drain, septic
128 system, French drain, dry well, or similar system that receives or has received fluid from a
129 facility engaged in vehicular repair or maintenance activities, including an auto body repair
130 shop, automotive repair shop, new and used car dealership, speciality repair shop, or any other
131 facility that does any vehicular repair work. A motor vehicle waste disposal well is subject to
132 rulemaking under Section 19-5-104 regarding underground injection."

133 [(H)] (12) In IPC, Section 202, the following definition is added: "Pollution (Low
134 Hazard). An impairment of the quality of the potable water to a degree that does not create a
135 hazard to the public health but that does adversely and unreasonably affect the aesthetic
136 qualities of such potable water for domestic use."

137 [(H)] (13) In IPC, Section 202, the definition for "Potable Water" is deleted and
138 replaced with the following: "Potable Water. Water free from impurities present in amounts
139 sufficient to cause disease or harmful physiological effects and conforming to the Utah Code,
140 Title 19, Chapter 4, Safe Drinking Water Act, and Title 19, Chapter 5, Water Quality Act, and
141 the regulations of the public health authority having jurisdiction."

142 Section 4. Section 15A-3-304 is amended to read:

143 **15A-3-304. Amendments to Chapter 4 of IPC.**

144 (1) In IPC, Table 403.1, the following changes are made:

145 (a) The title for Table 403.1 is deleted and replaced with the following: "Table 403.1,
146 Minimum Number of Required Plumbing Fixtures^{a, h}";

147 (b) In row number "3", for "E" occupancy, in the field for "OTHER", a new footnote g
148 is added.

149 (c) In row number "5", for "I-4 Adult day care and child day care" occupancy, in the
150 field for "OTHER", a new footnote g is added.

151 (d) A new footnote f is added as follows: "FOOTNOTE: f. When provided, in public
152 toilet facilities, there shall be an equal number of diaper changing facilities in male toilet rooms
153 and female toilet rooms. Diaper changing facilities shall meet the requirements of ASTM
154 F2285-04 (2010) Standard Consumer Safety Performance Specifications for Diaper Changing
155 Tables for Commercial Use."

156 (e) A new footnote g is added to the table as follows: "FOOTNOTE g: Non-residential
157 child care facilities shall comply with the additional requirements for sinks in administrative
158 rule made by the Department of Health."

159 (2) A new IPC, Section 406.3, is added as follows: " 406.3 Automatic clothes washer
160 safe pans. Safe pans, when installed under automatic clothes washers, shall be installed in
161 accordance with Section 504.7."

162 (3) A new IPC, Section 412.5, is added as follows: "412.5 Public toilet rooms. All
163 public toilet rooms in A & E occupancies and M occupancies with restrooms having multiple
164 water closets or urinals shall be equipped with at least one floor drain."

165 (4) A new IPC, Section 412.6, is added as follows: "Prohibition of Motor Vehicle
166 Waste Disposal Wells. New and existing motor vehicle waste disposal wells are prohibited. A
167 motor vehicle waste disposal well associated with a single family residence is not subject to
168 this prohibition.

169 [~~4~~] (5) IPC, Section 423.3, is deleted.

170 Section 5. Section **15A-3-601** is amended to read:

171 **15A-3-601. General provisions.**

172 The following are adopted as amendments to the NEC to be applicable statewide:

173 (1) The IRC provisions are adopted as the residential electrical standards applicable to
174 residential installations [~~applicable~~] under the IRC. All other installations shall comply with
175 the adopted NEC.

176 ~~[(2) NEC, Section 240.87(B), is modified to add the following as an additional~~
177 ~~approved equivalent means:]~~

178 ~~["6. An instantaneous trip function set at or below the available fault current."]~~

179 (2) In NEC, Section 210.8(B), the words "and three phase receptacles rated 150 volts to
180 ground or less, 100 amperes or less" are deleted.

181 (3) NEC, Section 210.71, is deleted.

182 (4) In NEC, Section 240.67, the words "January 1, 2020" are deleted and replaced with
183 "upon adoption of the 2020 NEC".