

26

27 *Be it enacted by the Legislature of the state of Utah:*

28 Section 1. Section **15A-3-104** is amended to read:

29 **15A-3-104. Amendments to Chapters 7 through 9 of IBC.**

30 (1) In IBC, Section ~~§~~→ [703.2.3] **704.13.2** ←~~§~~, the following sentence is added to the end
30a of the section:

31 "An individual spraying fire-resistant materials may obtain a certificate that demonstrates that
32 the individual has undergone training on how to spray fire-resistant materials to manufacturer's
33 specifications."

34 [(1)] (2) IBC, Section (F)901.8, is deleted and replaced with the following: "(F)901.8
35 Pump and riser room size. Fire pump and automatic sprinkler system riser rooms shall be
36 designed with adequate space for all installed equipment necessary for the installation and to
37 provide sufficient working space around the stationary equipment. Clearances around
38 equipment shall be in accordance with manufacturer requirements and not less than the
39 following minimum elements:

40 901.8.1 A minimum clear and unobstructed distance of 12-inches shall be provided from the
41 installed equipment to the elements of permanent construction.

42 901.8.2 A minimum clear and unobstructed distance of 12-inches shall be provided between
43 all other installed equipment and appliances.

44 901.8.3 A clear and unobstructed width of 36-inches shall be provided in front of all installed
45 equipment and appliances, to allow for inspection, service, repair or replacement without
46 removing such elements of permanent construction or disabling the function of a required
47 fire-resistance-rated assembly.

48 901.8.4 Automatic sprinkler system riser rooms shall be provided with a clear and
49 unobstructed passageway to the riser room of not less than 36-inches, and openings into the
50 room shall be clear and unobstructed, with doors swinging in the outward direction from the
51 room and the opening providing a clear width of not less than 34-inches and a clear height of
52 the door opening shall not be less than 80-inches.

53 901.8.5 Fire pump rooms shall be provided with a clear and unobstructed passageway to the
54 fire pump room of not less than 72-inches, and openings into the room shall be clear,
55 unobstructed and large enough to allow for the removal of the largest piece of equipment, with
56 doors swinging in the outward direction from the room and the opening providing a clear width